

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0822:129 Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: *Honeywell International Inc., 1985 Douglas Drive. N, Golden Valley, MN 5542
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-4713

DESIGN: Model 5600 inherently power-limited residential fire alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations.
System components:

5600	Control/Communicator
560, 565	Command Center
D133	Relay Module
D126	12V, 7Ah Battery
D110	Tamper Switch
D164	Phone Cord
D2103/8103	Enclosure
D8108A/8109	Enclosure
D127	Reversing Relay
D134	Relay Module
D208, D208LC	Zone Expander
D132	Smoke Detector Reverse Polarity Module
D1640	AC Transformer

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm control unit for use with separately listed compatible initiating and indicating devices.

NOTE:

1. For household system, Fire Alarm Verification feature (delay of alarm signal) is NOT approved for use in California.
2. Burglary and other non-fire functions were not examined.

XLF: 7167-0801:143

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager